



Example:

- Water flow rate 110 m³/h
- Inlet water temperature T_{w1} 31 °C
- Outlet water temperature T_{w2} 26 °C
- Temperature difference 5 K
- Wet bulb temperature T_F 18 °C
- Selected cooling tower HSB 46/03

ESOT - Invest d.o.o.
Kersnikova ulica 19
3000 Celje

Cooling towers
 HSB 34 + 72